

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16179

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/15/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 27 | 206-517G-199 ceiling panel white | Asbestos | None detected. This sample contains approx. 60% Mineral Wool, 30% Fiberglass, 10% Binder |
| 28 | 206-517G-200 ceiling panel, mastic brown | Asbestos | None detected. This sample contains approx. 3% Mineral Wool, 97% CaCO ₃ , Binder |
| 29 | 206-517G-201 plaster white | Asbestos | None detected. This sample contains approx. 2% Cellulose, 98% Perlite, Quartz, CaSO ₄ , Binder |
| 30 | 206-517G-202 covebase red | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |


*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16179

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/15/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 31 | 206-517G-203 covebase black | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ Binder |
| 32 | 206-517G-204 covebase mastic brown | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ |
| 33 | 206-517G-205 drywall, tape, compound white, lt. brown, white | Asbestos | * None detected. This sample contains approx. 35% Cellulose, 65% CaCO ₃ , CaSO ₄ , Binder |
| 34 | 206-517G-206 ceiling panel white | Asbestos | None detected. This sample contains approx. 60% Mineral Wool, 30% Fiberglass, 10% Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16179

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/15/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--------------------------------------|-----------|--|
| 35A | 206-517G-207 TSI tan | Asbestos | None detected. This sample contains approx. 30% Mineral Wool, 20% Fiberglass, 50% CaCO ₃ , Binder, Foam |
| 35B | 206-517G-207 TSI Wrap tan | Asbestos | None detected. This sample contains approx. 70% Cellulose, 30% Binder |
| 36 | 206-517G-208 ceiling panel tan | Asbestos | None detected. This sample contains approx. 40% Cellulose, 20% Mineral Wool, 20% Fiberglass, 20% Perlite, Binder |
| 37 | 206-517G-209 floor tile white | Asbestos | Positive. This sample contains approx. 3% Chrysotile, 97% Quartz, CaCO ₃ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16179

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/15/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 38 | 206-517G-210 floor tile mastic black | Asbestos | Positive. This sample contains approx. 10% Chrysotile, 90% CaCO ₃ , Binder |
| 39 | 206-517G-211 TSI tan | Asbestos | None detected. This sample contains approx. 20% Mineral Wool, 20% Fiberglass, 60% CaCO ₃ , Binder, Diatoms |
| 40 | 206-517G-212 paper, tar white, black | Asbestos | None detected. This sample contains approx. 50% Cellulose, 20% Fiberglass, 30% Binder, Tar |
| 41 | 206-517G-213 caulk beige | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 01 | 206-517G-214 ceiling tile lt. gray | Asbestos | None detected. This sample contains approx. 20% Cellulose, 20% Mineral Wool, 30% Fiberglass, 30% Perlite, Binder |
| 02 | 206-517G-215 floor tile beige | Asbestos | Positive. This sample contains approx. 3% Chrysotile, 97% Quartz, CaCO, Binder |
| 03 | 206-517G-216 floor tile mastic black | Asbestos | None detected. This sample contains approx. 2% Cellulose, 2% Fiberglass, 96% Quartz, CaCO, Binder |
| 04 | 206-517G-217 ceiling tile lt. brown | Asbestos | None detected. This sample contains approx. 20% Cellulose, 20% Mineral Wool, 25% Fiberglass, 35% Perlite, Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 05 | 206-517G-218 ceiling tile lt. gray | Asbestos | None detected. This sample contains approx. 30% Mineral Wool, 60% Fiberglass, 10% CaCO ₃ , Binder |
| 06 | 206-517G-219 ceiling tile mastic brown | Asbestos | None detected. This sample contains approx. trace Cellulose, 99% CaCO ₃ , Binder |
| 07 | 206-517G-220 plaster tan | Asbestos | None detected. This sample contains approx. 2% Cellulose, 98% Quartz, CaCO ₃ , CaSO ₄ |
| 08 | 206-517G-221 drywall, drywall compound white, lt. brown, off white | Asbestos | * None detected. This sample contains approx. 10% Cellulose, 90% CaCO ₃ , CaSO ₄ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 09 | 206-517G-222 covebase black | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |
| 10 | 206-517G-223 covebase mastic lt. brown, yellow | Asbestos | Trace detected. This sample contains approx. trace Tremolite, 2% Talc, 97% CaCO ₃ , Binder |
| 11 | 206-517G-224 covebase dk. gray | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |
| 12 | 206-517G-225 covebase mastic clear | Asbestos | None detected. This sample contains approx. 100% Binder |


*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS, TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|---|-----------|---|
| 13 | 206-517G-226 roofing material dk. brown | Asbestos | Positive. This sample contains approx. 15% Chrysotile, 5% Cellulose, 10% Fiberglass, 70% CaCO ₃ , Binder |
| 14 | 206-517G-227 insulation lt. brown | Asbestos | None detected. This sample contains approx. 30% Mineral Wool, 50% Fiberglass, 20% CaCO ₃ , Binder |
| 15 | 206-517G-228 TSI lt. brown | Asbestos | None detected. This sample contains approx. trace Cellulose, 15% Mineral Wool, 30% Fiberglass, 54% CaCO ₃ , Binder |
| 16 | 206-517G-229 TSI lt. gray | Asbestos | Positive. This sample contains approx. 40% Chrysotile, 50% Cellulose, 10% Binder |


*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|---|-----------|---|
| 17 | 206-517G-230 joint compound white | Asbestos | None detected. This sample contains approx. trace Cellulose, 2% Talc, 97% CaCO ₃ , Binder |
| 18 | 206-517G-231 plaster tan | Asbestos | None detected. This sample contains approx. 100% Quartz, CaCO ₃ , CaSO ₄ , Binder |
| 19 | 206-517G-232 gypsum board white | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , CaSO ₄ |
| 20 | 206-517G-233 ceiling tile white | Asbestos | None detected. This sample contains approx. 20% Mineral Wool, 75% Fiberglass, 5% CaCO ₃ , Binder |


*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94 Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 21 | 206-517G-234 floor tile tan | Asbestos | None detected. This sample contains approx. 100% Quartz , CaCO , Binder |
| 22 | 206-517G-235 floor tile mastic dk. brown | Asbestos | None detected. This sample contains approx. 100% CaCO , Binder |
| 23 | 206-517G-236 ceiling tile lt. brown | Asbestos | None detected. This sample contains approx. 40% Cellulose, 20% Mineral Wool, 20% Fiberglass, 20% Perlite , Binder |
| 24 | 206-517G-237 ceiling tile white | Asbestos | None detected. This sample contains approx. 10% Mineral Wool, 85% Fiberglass, 5% CaCO , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 25 | 206-517G-238 ceiling tile mastic brown | Asbestos | None detected. This sample contains approx. 5% Fiberglass, 95% CaCO ₃ , Binder |
| 26 | 206-517G-239 plaster tan | Asbestos | None detected. This sample contains approx. 2% Cellulose, 98% Quartz, CaCO ₃ , CaSO ₄ , Binder |
| 27 | 206-517G-240 covebase black | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |
| 28 | 206-517F-241 fiber board brown | Asbestos | None detected. This sample contains approx. 99% Cellulose, 1% Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94


Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 29 | 206-517G-242 covebase mastic brown | Asbestos | Trace detected. This sample contains approx. trace Tremolite, 3% Talc, 96% CaCO ₃ , Binder |
| 30 | 206-517G-243 floor tile beige | Asbestos | Positive. This sample contains approx. 2% Chrysotile, 98% Quartz, CaCO ₃ , Binder |
| 31 | 206-517G-244 floor tile mastic black | Asbestos | None detected. This sample contains approx. 2% Cellulose, 98% Quartz, CaCO ₃ , Binder |
| 32 | 206-517G-245 tape, drywall compound off white, white | Asbestos | * Positive. This sample contains approx. 5% Chrysotile, 6% Cellulose, 89% CaCO ₃ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS, TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--------------------------------------|-----------|--|
| 33A | 206-517G-246 TSI Wrap white | Asbestos | None detected. This sample contains approx. 98% Cellulose, 2% Binder |
| 33B | 206-517G-246 mastic black | Asbestos | None detected. This sample contains approx. 30% Cellulose, 5% Mineral Wool, 10% Fiberglass, 55% Quartz, CaCO ₃ , Binder |
| 33C | 206-517G-246 insulation orange | Asbestos | None detected. This sample contains approx. 60% Mineral Wool, 35% Fiberglass, 5% Binder |
| 34A | 206-517G-247 TSI Wrap white | Asbestos | None detected. This sample contains approx. 98% Cellulose, 2% Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|---------------------------------------|-----------|---|
| 34B | 206-517G-247 TSI lt. gray | Asbestos | None detected. This sample contains approx. trace Cellulose, 15% Mineral Wool, 25% Fiberglass, 59% CaCO ₃ , Binder |
| 35 | 206-517G-248 plaster white, tan | Asbestos | None detected. This sample contains approx. trace Cellulose, 99% Quartz, CaCO ₃ , CaSO ₄ , Binder |
| 36 | 206-517G-249 plaster white, tan | Asbestos | None detected. This sample contains approx. trace Cellulose, 99% Quartz, CaCO ₃ , CaSO ₄ , Binder |
| 37 | 206-517G-250 floor tile beige | Asbestos | Positive. This sample contains approx. 3% Chrysotile, 97% Quartz, CaCO ₃ , Binder |


*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

ENVIRONMENTAL MANAGEMENT CONSULTANTS
BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 38 | 206-517G-251 floor tile mastic black | Asbestos | Positive. This sample contains approx. 10% Chrysotile, 15% Cellulose, 75% CaCO ₃ , Binder |
| 39A | 206-517G-252 TSI Wrap off white | Asbestos | None detected. This sample contains approx. 98% Cellulose, 2% Binder |
| 39B | 206-517G-252 TSI lt. gray | Asbestos | None detected. This sample contains approx. 10% Mineral Wool, 30% Fiberglass, 60% CaCO ₃ , Binder, Diatoms |
| 40 | 206-517G-253 plaster white | Asbestos | None detected. This sample contains approx. 1% Cellulose, 99% Quartz, CaCO ₃ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS, TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 41 | 206-517G-254 plaster white, brown | Asbestos | None detected. This sample contains approx. 100% Quartz, CaSO, Binder |
| 42 | 206-517G-255 ceiling tile lt. brown | Asbestos | None detected. This sample contains approx. 40% Cellulose, 10% Mineral Wool, 25% Fiberglass, 25% Perlite, Binder |
| 43 | 206-517G-256 floor tile beige | Asbestos | Positive. This sample contains approx. 2% Chrysotile, 98% Quartz, CaCO, Binder |
| 44 | 206-517G-257 floor tile mastic black | Asbestos | Trace detected. This sample contains approx. trace Chrysotile, 2% Cellulose, 97% Quartz, CaCO , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|---------------------------------------|-----------|---|
| 45 | 206-517G-258 ceiling tile white | Asbestos | None detected. This sample contains approx. 2% Cellulose, 10% Mineral Wool, 80% Fiberglass, 8% CaCO ₃ , Binder |
| 46 | 206-517G-259 plaster white, tan | Asbestos | None detected. This sample contains approx. 100% Quartz, CaCO ₃ , CaSO ₄ , Binder |
| 47 | 206-517G-260 plaster tan | Asbestos | None detected. This sample contains approx. trace Cellulose, 99% Quartz, CaCO ₃ , CaSO ₄ , Binder |
| 48 | 206-517G-261 drywall white | Asbestos | None detected. This sample contains approx. 2% Cellulose, 98% CaCO ₃ , CaSO ₄ |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|---|-----------|---|
| 49 | 206-517G-262 stucco beige | Asbestos | None detected. This sample contains approx. 100% Quartz , CaCO , CaSO , Binder |
| 50 | 206-517G-263 ceiling tile lt. brown | Asbestos | None detected. This sample contains approx. 20% Cellulose, 10% Mineral Wool, 20% Fiberglass, 50% Perlite , Binder |
| 51 | 206-517G-264 covebase black | Asbestos | None detected. This sample contains approx. trace Cellulose, 99% CaCO , Binder |
| 52 | 206-517G-265 covebase mastic brown | Asbestos | Trace detected. This sample contains approx. trace Tremolite, 5% Talc, 94% CaCO , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 53 | 206-517G-266 TSI | Asbestos | None detected. This sample contains approx. 20% Mineral Wool, 20% Fiberglass, 60% CaCO ₃ , Binder, Diatoms |
| 54 | 206-517G-267 floor tile gray | Asbestos | Positive. This sample contains approx. 2% Chrysotile, 98% Quartz, CaCO ₃ , Binder |
| 55 | 206-517G-268 floor tile mastic black | Asbestos | None detected. This sample contains approx. 2% Cellulose, 98% Quartz, CaCO ₃ , Binder |
| 56 | 206-517G-269 floor tile tan | Asbestos | None detected. This sample contains approx. trace Cellulose, 99% Quartz, CaCO ₃ |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|---|-----------|--|
| 57 | 206-517G-270 floor tile mastic brown | Asbestos | None detected. This sample contains approx. trace Cellulose, 99% CaCO ₃ , Binder |
| 58 | 206-517G-271 ceiling tile white | Asbestos | None detected. This sample contains approx. trace Cellulose, 20% Mineral Wool, 75% Fiberglass, 4% CaCO ₃ , Binder |
| 59 | 206-517G-272 ceiling tile lt. brown | Asbestos | None detected. This sample contains approx. 30% Cellulose, 15% Mineral Wool, 30% Fiberglass, 25% Perlite, Binder |
| 60A | 206-517G-273 drywall white, lt. brown | Asbestos | None detected. This sample contains approx. 10% Cellulose, 90% CaCO ₃ , CaSO ₄ |


*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|---|-----------|--|
| 60B | 206-517G-273 drywall compound off white | Asbestos | None detected. This sample contains approx. 2% Cellulose, 98% CaCO ₃ , Binder |
| 61 | 206-517G-274 mastic brown | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |
| 62 | 206-517G-275 plaster tan | Asbestos | None detected. This sample contains approx. 100% Quartz, CaCO ₃ , CaSO ₄ , Binder |
| 63 | 206-517G-276 floor tile beige | Asbestos | Positive. This sample contains approx. 3% Chrysotile, 97% Quartz, CaCO ₃ , Binder |


*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS, TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 64 | 206-517G-277 floor tile mastic black | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |
| 65 | 206-517G-278 drywall white, brown | Asbestos | None detected. This sample contains approx. 15% Cellulose, 85% CaCO ₃ , CaSO ₄ |
| 66 | 206-517G-279 ceiling tile white | Asbestos | None detected. This sample contains approx. 20% Mineral Wool, 70% Fiberglass, 10% CaCO ₃ , Binder |
| 67 | 206-517G-280 plaster white | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , CaSO ₄ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|-----------------------------------|-----------|---|
| 68 | 206-517G-281 plaster tan | Asbestos | None detected. This sample contains approx. 100% Quartz , CaCO , CaSO , Binder |
| 69A | 206-517G-282 TSI Wrap white | Asbestos | None detected. This sample contains approx. 98% Cellulose, 2% Binder |
| 69B | 206-517G-282 mastic black | Asbestos | None detected. This sample contains approx. 30% Fiberglass, 70% Binder |
| 69C | 206-517G-282 TSI orange | Asbestos | None detected. This sample contains approx. 98% Fiberglass, 2% Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 70A | 206-517G-283 TSI Wrap white | Asbestos | None detected. This sample contains approx. 98% Cellulose, 2% Binder |
| 70B | 206-517G-283 TSI lt. gray | Asbestos | None detected. This sample contains approx. 20% Mineral Wool, 20% Fiberglass, 60% CaCO ₃ , Binder |
| 71A | 206-517G-284 vapor barrier black | Asbestos | Positive. This sample contains approx. 30% Chrysotile, 2% Cellulose, 68% CaCO ₃ , Binder |
| 71B | 206-517G-284 insulation orange | Asbestos | None detected. This sample contains approx. 98% Fiberglass, 2% Binder |


*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 72 | 206-517G-285 floor tile beige | Asbestos | Positive. This sample contains approx. 5% Chrysotile, 95% Quartz, CaCO, Binder |
| 73 | 206-517G-286 floor tile mastic black | Asbestos | Positive. This sample contains approx. 3% Chrysotile, 10% Cellulose, 3% Synthetics, 84% Quartz, CaCO, Binder |
| 74 | 206-517G-287 plaster white | Asbestos | None detected. This sample contains approx. 100% Quartz, CaCO, CaSO, Binder |
| 75 | 206-517G-288 drywall white | Asbestos | None detected. This sample contains approx. trace Cellulose, 99% CaCO, CaSO |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|---|-----------|--|
| 76 | 206-517G-289 plaster off white | Asbestos | None detected. This sample contains approx. 2% Wollastonite, 98% CaCO ₃ , CaSO ₄ , Binder |
| 77 | 206-517G-290 stucco brown | Asbestos | None detected. This sample contains approx. 100% Quartz, CaCO ₃ , CaSO ₄ , Binder |
| 78 | 206-517G-291 covebase dk. gray | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |
| 79 | 206-517G-292 covebase mastic yellow | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS, TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|---|-----------|--|
| 80 | 206-517G-293 mastic brown | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |
| 81 | 206-517G-294 plaster off white | Asbestos | None detected. This sample contains approx. 100% Quartz, CaCO ₃ , CaSO ₄ , Binder |
| 82 | 206-517G-295 ceiling tile off white | Asbestos | None detected. This sample contains approx. 40% Cellulose, 10% Mineral Wool, 40% Fiberglass, 10% Perlite, Binder |
| 83 | 206-517G-296 floor tile white | Asbestos | Positive. This sample contains approx. 3% Chrysotile, 2% Wollastonite, 95% Quartz, CaCO ₃ , Binder |


*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS . TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94


Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 84 | 206-517G-297 floor tile mastic black | Asbestos | None detected. This sample contains approx. trace Cellulose, 99% Quartz, CaCO, Binder |
| 85 | 206-517G-298 ceiling tile white | Asbestos | None detected. This sample contains approx. 10% Mineral Wool, 85% Fiberglass, 5% CaCO, Binder |
| 86 | 206-517G-299 plaster white, tan | Asbestos | None detected. This sample contains approx. 100% Quartz, CaCO, CaSO, Binder |
| 87 | 206-517G-300 plaster tan | Asbestos | None detected. This sample contains approx. 100% Quartz, CaCO, CaSO, Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|---|-----------|--|
| 88 | 206-517G-301 covebase dk. brown | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |
| 89 | 206-517G-302 covebase mastic yellow | Asbestos | None detected. This sample contains approx. 10% Cellulose, 90% CaCO ₃ , Binder |
| 90A | 206-517G-303 TSI Wrap white | Asbestos | None detected. This sample contains approx. 98% Cellulose, 2% Binder |
| 90B | 206-517G-303 mastic black | Asbestos | None detected. This sample contains approx. 20% Fiberglass, 80% Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NV/LAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 90C | 206-517G-303 TSI orange | Asbestos | None detected. This sample contains approx. 98% Fiberglass, 2% Binder |
| 91 | 206-517G-304 TSI lt. brown | Asbestos | None detected. This sample contains approx. 30% Mineral Wool, 20% Fiberglass, 50% CaCO ₃ , Binder, Diatoms |
| 92A | 206-517G-305 vapor barrier black | Asbestos | Positive. This sample contains approx. 30% Chrysotile, 5% Cellulose, 65% CaCO ₃ , Binder |
| 92B | 206-517G-305 insulation orange | Asbestos | None detected. This sample contains approx. 2% Cellulose, 97% Fiberglass, 1% Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS, TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16185

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94 Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|---|-----------|---|
| 93 | 206-517G-306 ceiling tile lt. brown | Asbestos | None detected. This sample contains approx. 40% Cellulose, 20% Mineral Wool, 25% Fiberglass, 15% Perlite , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 01 | 206-517G-307 joint compound beige, white | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |
| 02 | 206-517G-308 covebase brown | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |
| 03 | 206-517G-309 covebase mastic yellow | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |
| 04 | 206-517G-310 ceiling tile white | Asbestos | None detected. This sample contains approx. 30% Mineral Wool, 65% Fiberglass, 5% CaCO ₃ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|-------------------------------------|-----------|---|
| 05 | 206-517G-311 mastic brown | Asbestos | None detected. This sample contains approx. 2% Mineral Wool, 2% Fiberglass, 96% Binder |
| 06 | 206-517G-312 plaster white | Asbestos | None detected. This sample contains approx. 100% Perlite , Quartz , Binder |
| 07 | 206-517G-313 ceiling tile tan | Asbestos | None detected. This sample contains approx. 40% Cellulose, 10% Mineral Wool, 30% Fiberglass, 20% Perlite , Binder |
| 08 | 206-517G-314 floor tile white | Asbestos | Positive. This sample contains approx. 2% Chrysotile, 98% Quartz , CaCO , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 09 | 206-517G-315 floor tile mastic black | Asbestos | Positive. This sample contains approx. 5% Chrysotile, 95% Quartz, CaCO ₃ , Binder |
| 10 | 206-517G-316 ceiling tile tan | Asbestos | None detected. This sample contains approx. 40% Cellulose, 10% Mineral Wool, 30% Fiberglass, 20% Perlite, Binder |
| 11 | 206-517G-317 drywall white | Asbestos | None detected. This sample contains approx. 3% Cellulose, 97% CaCO ₃ , CaSO ₄ |
| 12 | 206-517G-318 plaster white | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , CaSO ₄ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS .TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 13 | 206-517G-319 plaster tan | Asbestos | None detected. This sample contains approx. 100% Quartz, CaCO, CaSO, Binder |
| 14 | 206-517G-320 ceiling tile tan | Asbestos | None detected. This sample contains approx. 40% Cellulose, 10% Mineral Wool, 30% Fiberglass, 20% Perlite, Binder |
| 15 | 206-517G-321 drywall, tape, compound white, lt. brown, tan | Asbestos | * Trace detected. This sample contains approx. trace Chrysotile, 23% Cellulose, 76% Quartz, CaCO, CaSO, Binder |
| 16 | 206-517G-322 TSI white | Asbestos | Positive. This sample contains approx. 10% Chrysotile, 10% Mineral Wool, 30% Fiberglass, 50% CaCO, Binder, Diatoms |


*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94 Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 17 | 206-517G-323 plaster white | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , CaSO ₄ , Binder |
| 18 | 206-517G-324 plaster tan | Asbestos | None detected. This sample contains approx. 100% Quartz, CaCO ₃ , CaSO ₄ , Binder |
| 19 | 206-517G-325 drywall, tape, compound white, tan, white | Asbestos | * None detected. This sample contains approx. 35% Cellulose, 65% CaCO ₃ , CaSO ₄ , Binder |
| 20 | 206-517G-326 plaster white | Asbestos | None detected. This sample contains approx. 5% Cellulose, 95% CaSO ₄ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 21 | 206-517G-327 plaster tan | Asbestos | None detected. This sample contains approx. 100% Quartz , CaSO , Binder |
| 22 | 206-517G-328 floor tile white | Asbestos | Positive. This sample contains approx. 3% Chrysotile, 97% Quartz , CaCO , Binder |
| 23 | 206-517G-329 floor tile mastic black | Asbestos | Positive. This sample contains approx. 10% Chrysotile, 90% CaCO , Binder |
| 24 | 206-517G-330 floor tile yellow | Asbestos | None detected. This sample contains approx. 100% Quartz , CaCO , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS .TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 25 | 206-517G-331 floor tile mastic black | Asbestos | None detected. This sample contains approx. 5% Cellulose, 95% CaCO ₃ , Binder |
| 26 | 206-517G-332 ceiling tile white | Asbestos | None detected. This sample contains approx. 10% Mineral Wool, 80% Fiberglass, 10% CaCO ₃ , Binder |
| 27 | 206-517G-333 ceiling tile white | Asbestos | None detected. This sample contains approx. 10% Mineral Wool, 80% Fiberglass, 10% CaCO ₃ , Binder |
| 28 | 206-517G-334 mastic brown | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS, TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 29 | 206-517G-335 plaster white | Asbestos | None detected. This sample contains approx. 100% Perlite , Quartz , CaSO , Binder |
| 30 | 206-517G-336 ceiling tile tan | Asbestos | None detected. This sample contains approx. 40% Cellulose, 10% Mineral Wool, 30% Fiberglass, 20% Perlite , Binder |
| 31 | 206-517G-337 floor tile blue | Asbestos | Positive. This sample contains approx. 5% Chrysotile, 95% Quartz , CaCO , Binder |
| 32 | 206-517G-338 floor tile mastic black | Asbestos | None detected. This sample contains approx. 100% Quartz , CaCO , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|-------------------------------------|-----------|---|
| 33 | 206-517G-339 ceiling tile tan | Asbestos | None detected. This sample contains approx. 40% Cellulose, 10% Mineral Wool, 30% Fiberglass, 20% Perlite , Binder |
| 34 | 206-517G-340 plaster white | Asbestos | None detected. This sample contains approx. 100% Quartz , CaCO , CaSO , Binder |
| 35 | 206-517G-341 plaster tan | Asbestos | None detected. This sample contains approx. 100% Quartz , CaSO , Glass Fragments |
| 36 | 206-517G-342 covebase black | Asbestos | None detected. This sample contains approx. 100% CaCO , Binder |


*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 37 | 206-517G-343 covebase mastic lt. brown | Asbestos | Trace detected. This sample contains approx. trace Tremolite, 10% Talc, 89% Binder |
| 38 | 206-517G-344 drywall, tape, compound white, lt. brown, tan | Asbestos | * None detected. This sample contains approx. 36% Cellulose, 64% CaCO ₃ , CaSO ₄ , Binder |
| 39 | 206-517G-345 TSI tan | Asbestos | Positive. This sample contains approx. 5% Chrysotile, 10% Mineral Wool, 30% Fiberglass, 55% CaCO ₃ , Binder, Diatoms |
| 40 | 206-517G-346 TSI tan | Asbestos | Positive. This sample contains approx. 3% Chrysotile, 97% CaCO ₃ , Binder, Diatoms |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS, TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--------------------------------------|-----------|---|
| 41 | 206-517G-347 wrap tan | Asbestos | None detected. This sample contains approx. 80% Cellulose, 3% Fiberglass, 17% CaCO ₃ , Binder |
| 42 | 206-517G-348 TSI tan | Asbestos | Positive. This sample contains approx. 5% Chrysotile, 10% Mineral Wool, 40% Fiberglass, 45% CaCO ₃ , Binder, Diatoms |
| 43 | 206-517G-349 plaster white | Asbestos | None detected. This sample contains approx. 5% Cellulose, 95% CaCO ₃ , CaSO ₄ , Binder |
| 44 | 206-517G-350 floor tile yellow | Asbestos | None detected. This sample contains approx. 100% Quartz, CaCO ₃ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 45 | 206-517G-351 floor tile mastic brown | Asbestos | None detected. This sample contains approx. 3% Cellulose, 97% Binder |
| 46 | 206-517G-352 ceiling tile white | Asbestos | None detected. This sample contains approx. 30% Mineral Wool, 60% Fiberglass, 10% CaCO ₃ , Binder |
| 47 | 206-517G-353 drywall, tape, compound white, lt. brown, white | Asbestos | * Trace detected. This sample contains approx. trace Chrysotile, 27% Cellulose, 72% CaCO ₃ , CaSO ₄ , Binder |
| 48 | 206-517G-354 ceiling tile white | Asbestos | None detected. This sample contains approx. 30% Mineral Wool, 65% Fiberglass, 5% CaCO ₃ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 49 | 206-517G-355 ceiling tile mastic brown | Asbestos | None detected. This sample contains approx. 3% Mineral Wool, 97% CaCO ₃ , Binder |
| 50 | 206-517G-356 plaster white | Asbestos | None detected. This sample contains approx. 100% Perlite, Quartz, CaCO ₃ , CaSO ₄ |
| 51 | 206-517G-357 floor tile blue | Asbestos | Positive. This sample contains approx. 3% Chrysotile, 97% Quartz, CaCO ₃ , Binder |
| 52 | 206-517G-358 floor tile mastic black | Asbestos | None detected. This sample contains approx. 5% Cellulose, 95% CaCO ₃ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS, TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|----------------------------------|-----------|---|
| 53 | 206-517G-359 plaster white | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , CaSO ₄ , Binder |
| 54 | 206-517G-360 plaster tan | Asbestos | None detected. This sample contains approx. 100% Quartz, CaSO ₄ , Binder, Glass Fragments |
| 55 | 206-517G-361 plaster white | Asbestos | None detected. This sample contains approx. 5% Cellulose, 95% Quartz, CaCO ₃ , CaSO ₄ |
| 56 | 206-517G-362 TSI tan | Asbestos | None detected. This sample contains approx. 2% Cellulose, 40% Mineral Wool, 10% Fiberglass, 48% Quartz, CaCO ₃ , Binder, Diatoms |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS, TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94 Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|---|-----------|--|
| 57 | 206-517G-363 mastic black | Asbestos | Positive. This sample contains approx. 10% Chrysotile, 30% Fiberglass, 60% CaCO ₃ , Binder, Tar |
| 58 | 206-517G-364 insulation brown | Asbestos | None detected. This sample contains approx. 3% Cellulose, 90% Fiberglass, 7% Binder |
| 59 | 206-517G-365 covebase black | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |
| 60 | 206-517G-366 covebase mastic yellow | Asbestos | None detected. This sample contains approx. 5% Cellulose, 3% Mineral Wool, 92% CaCO ₃ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 61 | 206-517G-367 tan | Asbestos | None detected. This sample contains approx. 40% Cellulose, 20% Mineral Wool, 20% Fiberglass, 20% Perlite , Binder |
| 62 | 206-517G-368 floor tile white | Asbestos | Positive. This sample contains approx. 3% Chrysotile, 97% Quartz , CaCO , Binder |
| 63 | 206-517G-369 floor tile mastic black | Asbestos | Positive. This sample contains approx. 10% Chrysotile, 3% Cellulose, 3% Synthetics, 84% CaCO , Binder |
| 64 | 206-517G-370 plaster white | Asbestos | None detected. This sample contains approx. 100% CaCO , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 65 | 206-517G-371 transite lt. brown, white | Asbestos | Positive. This sample contains approx. 30% Chrysotile, 70% CaCO ₃ , Binder |
| 66 | 206-517G-372 mastic brown | Asbestos | Trace detected. This sample contains approx. trace Tremolite, 10% Talc, 89% CaCO ₃ , Binder |
| 67 | 206-517G-373 plaster white | Asbestos | None detected. This sample contains approx. 100% Perlite, Quartz, CaSO ₄ , Binder |
| 68 | 206-517G-374 plaster white | Asbestos | None detected. This sample contains approx. 100% Quartz, CaCO ₃ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS, TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16180

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/18/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 69 | 206-517G-375 transite lt. brown, white | Asbestos | Positive. This sample contains approx. 30% Chrysotile, 70% CaCO ₃ , Binder |
| 70 | 206-517G-376 plaster tan | Asbestos | None detected. This sample contains approx. 100% Quartz, CaCO ₃ , Binder |
| 71 | 206-517G-377 caulk brown | Asbestos | None detected. This sample contains approx. 100% CaCO ₃ , Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Kurt Kettler



By: Russell Nassof

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16178

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/17/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 01A | 206-517G-378 pipe cover beige, off white | Asbestos | Positive. This sample contains approx. 5% Chrysotile, 50% Cellulose, 20% Fiberglass, 25% Quartz, CaCO, CaSO, Diatoms |
| 01B | 206-517G-378 pipe insulation gray | Asbestos | Positive. This sample contains approx. 5% Chrysotile, 40% Fiberglass, 55% Quartz, CaCO , CaSO, Binder |
| 02 | 206-517G-379 roof mastic gray, black | Asbestos | None detected. This sample contains approx. 3% Cellulose, 97% Quartz, Binder |
| 03 | 206-517G-380 insulation black | Asbestos | None detected. This sample contains approx. 2% Cellulose, 98% Quartz, Binder |

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Ken Hokanson



By: Kurt Kettler

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16178

Methodology: EPA 600/M4-8

P/O#:

Proj: 206

By: Client


Received: 11/8/94

Reported: 11/1

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|---|-----------|---|
| 04A | 206-517G-381 pipe cover beige | Asbestos | None detected. This sample contains app: 60% Cellulose, 20% Fiberglass, 20% Qua , CaSO , Binder , Diatoms |
| 04B | 206-517G-381 pipe insulation gray | Asbestos | None detected. This sample contains app 40% Fiberglass, 60% Quartz , CaCO , Ca Diatoms |
| 05 | 206-517G-382 transite panel gray | Asbestos | Positive. This sample contains approx. 20% Chrysotile, 80% Quartz , CaCO , Ca Binder |
| 06 | 206-517G-383 pipe insulation lt. gray | Asbestos | None detected. This sample contains app: 30% Fiberglass, 70% Quartz , CaCO , Ca |

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REF OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Ken Hokanson



By: Kurt Kettler

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16178

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client


Received: 11/8/94

Reported: 11/17/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 07A | 206-517G-384 pipe cover beige | Asbestos | None detected. This sample contains approx. 60% Cellulose, 20% Fiberglass, 20% Quartz , CaCO , CaSO , Diatoms |
| 07B | 206-517G-384 pipe insulation dk. gray | Asbestos | None detected. This sample contains approx. 40% Fiberglass, 60% Quartz , CaCO , CaSO , Diatoms |
| 08A | 206-517G-385 roofing material white, black | Asbestos | None detected. This sample contains approx. 10% Fiberglass, 90% Quartz , CaCO , Binder |
| 08B | 206-517G-385 roofing felt black | Asbestos | None detected. This sample contains approx. 20% Fiberglass, 80% Quartz , Binder |

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Ken Hokanson



By: Kurt Kettler

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16178

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94 Reported: 11/17/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 08C | 206-517G-385 roofing, insulation brown | Asbestos | None detected. This sample contains approx. 60% Cellulose, 40% Perlite, Binder |
| 09A | 206-517G-386 roofing material white, black | Asbestos | None detected. This sample contains approx. 20% Fiberglass, 80% Quartz, CaCO, Binder |
| 09B | 206-517G-386 roofing felt black | Asbestos | None detected. This sample contains approx. 20% Fiberglass, 80% Quartz, Binder |
| 09C | 206-517G-386 roofing felt black | Asbestos | None detected. This sample contains approx. 20% Fiberglass, 80% Quartz, Binder |

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Ken Hokanson



By: Kurt Kettler

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16178

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/17/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|---|-----------|--|
| 09D | 206-517G-386 roofing felt black | Asbestos | None detected. This sample contains approx. 20% Fiberglass, 80% Quartz , Binder |
| 09E | 206-517G-386 roofing, insulation brown | Asbestos | None detected. This sample contains approx. 60% Cellulose, 40% Perlite , Binder |
| 10 | 206-517G-387 roof mastic dk. brown, black | Asbestos | None detected. This sample contains approx. 15% Cellulose, 85% Quartz , CaCO , Binder |
| 11 | 206-517G-388 roof mastic dk. brown, black | Asbestos | None detected. This sample contains approx. 15% Cellulose, 85% Quartz , CaCO , Binder |

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Ken Hokanson



By: Kurt Kettler

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16178

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/17/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 12 | 206-517G-389 insulation dk. brown | Asbestos | None detected. This sample contains approx. 80% Cellulose, 20% Quartz, Binder |
| 13A | 206-517G-390 roofing material white, black | Asbestos | None detected. This sample contains approx. 10% Fiberglass, 90% Quartz, CaCO, Binder |
| 13B | 206-517G-390 roofing felt black | Asbestos | None detected. This sample contains approx. 10% Fiberglass, 90% Quartz, Binder |
| 13C | 206-517G-390 roofing felt black | Asbestos | None detected. This sample contains approx. 20% Fiberglass, 80% Quartz, Binder |

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Ken Hokanson



By: Kurt Kettler

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16178

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 11/8/94

Reported: 11/17/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|---|
| 13D | 206-517G-390 roofing felt black | Asbestos | None detected. This sample contains approx. 20% Fiberglass, 80% Quartz, Binder |
| 13E | 206-517G-390 roofing, insulation brown | Asbestos | None detected. This sample contains approx. 70% Cellulose, 30% Perlite, Binder |
| 14A | 206-517G-391 roofing material white, black | Asbestos | None detected. This sample contains approx. 10% Fiberglass, 90% Quartz, CaCO ₃ , Binder |
| 14B | 206-517G-391 roofing felt black | Asbestos | None detected. This sample contains approx. 20% Fiberglass, 80% Quartz, Binder |

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Ken Hokanson



By: Kurt Kettler

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16178

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206

By: Client


Received: 11/8/94

Reported: 11/17/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|---|-----------|--|
| 14C | 206-517G-391 roofing felt black | Asbestos | None detected. This sample contains approx. 20% Fiberglass, 80% Quartz , Binder |
| 14D | 206-517G-391 roofing, insulation brown | Asbestos | None detected. This sample contains approx. 60% Cellulose, 40% Perlite , Binder |
| 15 | 206-517G-392 roof mastic silver, black | Asbestos | None detected. This sample contains approx. 15% Cellulose, 85% Quartz , CaCO , Binder |
| 16 | 206-517G-393 roof mastic dk. brown, black | Asbestos | None detected. This sample contains approx. 15% Cellulose, 85% Quartz , CaCO , Binder |

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS , TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Ken Hokanson



By: Kurt Kettler

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

11/11/94

ENVIRONMENTAL MANAGEMENT CONSULTANTS

Page 1 of 1

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from:

Shipped via: FEDERAL EXPRESS

LAB: 16221

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206


By: Client

Received: 11/10/94 Reported: 11/11/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|-------------------------------------|-----------|---|
| 01 | 206-517G-394 insulation white | Asbestos | Positive. This sample contains approx. 10% Chrysotile, 25% Amosite, 10% Cellulose, 55% CaSO ₄ Binder |

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Al Glyda



By: Kurt Kettler

NVLAP Accreditation #1926, CA ELAP #1913, NY ELAP #11445, TX DOH #30-0094

4455 EAST CAMELBACK ROAD, SUITE D-155 PHOENIX, ARIZONA 85018 (602) 840-8012 FAX: (602) 990-8468

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16308

Methodology: EPA 600/M4-82-020

P/O#:

Proj: 206


By: Client

Received: 11/15/94 Reported: 11/16/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|---|-----------|--|
| 01 | 206-517G-395 pipe insulation gray | Asbestos | None detected. This sample contains approx. 10% Cellulose, 30% Fiberglass, 60% CaSO ₄ , Binder |
| 02 | 206-517G-396 pipe insulation gray | Asbestos | None detected. This sample contains approx. 5% Cellulose, 30% Fiberglass, 65% Quartz, CaSO ₄ |

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.



Analyst: Ken Scheske



By: Kurt Kettler

BULK MATERIAL REPORT

REPORT Laboratory Analysis: BULK MATERIAL

Client: R & H ASSOCIATES

Reported to: Ron Holtz

Sampled from: 206

Shipped via: FEDERAL EXPRESS

LAB: 16684

Methodology: EPA 800/M4-82-020

P/O#:

Proj: 206

By: Client

Received: 12/6/94

Reported: 12/8/94

| SAMPLE | IDENTIFICATION | PARAMETER | TEST RESULTS |
|--------|--|-----------|--|
| 01 | 206-517G-397 insulation off white | Asbestos | None detected. This sample contains approx. 20% Mineral Wool, 30% Fiberglass, 50% Quartz, CaSO, Binder |
| 02 | 206-517G-398 drywall, drywall tape, drywall comp white, white, white | Asbestos | * Trace detected. This sample contains approx. trace Chrysotile, 17% Cellulose, 82% Quartz, CaCO, CaSO, Mica, Binder |

*FOR COMPOSITE ANALYSIS: THIS SAMPLE IS INHOMOGENEOUS. EACH LAYER WAS ANALYZED INDIVIDUALLY AND A COMPOSITE RESULTS WAS REPORTED.

THE REPORT APPLIES TO THE STANDARDS OR PROCEDURES IDENTIFIED AND TO THE SAMPLE(S) TESTED. THE TEST RESULTS ARE NOT NECESSARILY INDICATIVE OR REPRESENTATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN OR OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE RENDERED UPON THE CONDITION THAT THEY WILL NOT BE REPRODUCED WHOLLY OR IN PART FOR ADVERTISING OR OTHER PURPOSES OVER OUR SIGNATURE OR IN CONNECTION WITH OUR NAME WITHOUT SPECIAL WRITTEN PERMISSION. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS.

ACCREDITED BY THE NATIONAL INSTITUTE OF STANDARDS, TECHNOLOGY, VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SELECTED TEST METHOD FOR ASBESTOS. THE ACCREDITATION OR ANY REPORTS GENERATED BY THIS LABORATORY IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY. ALL ANALYSES ARE DERIVED FROM CALIBRATED VISUAL ESTIMATE UNLESS OTHERWISE NOTED. POLARIZED-LIGHT IS NOT CONSISTENTLY RELIABLE IN DETECTING ASBESTOS IN FLOOR COVERINGS AND SIMILAR NON-FRIABLE ORGANICALLY BOUND MATERIALS. QUANTITATIVE TRANSMISSION ELECTRON MICROSCOPY IS CURRENTLY THE ONLY METHOD THAT CAN BE USED TO DETERMINE IF THIS MATERIAL CAN BE CONSIDERED OR TREATED AS NON-ASBESTOS-CONTAINING.

Analyst: Al Glyda

By: Kurt Kettler